



NOTE:  
 PROVIDE FIRE EXTINGUISHERS AT MINIMUM OF 75' (TRAVEL DISTANCE) INTERVALS AND AT LOCATIONS AS REQUIRED BY FIRE MARSHAL.

**1** TYPICAL UPPER FLOOR EGRESS PLAN

SCALE: 1/8" = 1'-0"

