

DOOR SCHEDULE - GUESTROOMS

DOOR #	LOCATION	TYPE	DOOR				FRAME				FIRE RATING	HW SET	REMARKS		
			WIDTH	HEIGHT	THKNS	MATERIAL	FINISH	DETAILS		TYPE/ MATERIAL				FINISH	
								HEAD	JAMB						SILL
G01A	GUESTROOM ENTRY	DP G	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	1	
G01B	GUESTROOM ENTRY	DP G	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	45 MIN.	1	
G02A	GUEST BATH (SWING)	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXG2-PL01	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXG2-PT01	NO RATING	2	
G02B	GUEST BATH (SLIDING)	DP F SD B	3'-6"	6'-8"	1 3/8"	SCWD	EXG2-PL01	N/A	N/A	1/1D010 (SIM)	N/A	EXG2-PT01	NO RATING	3	COORDINATE SLIDING DR TRACK MOUNTING HT W/ CEILING HT; FLOOR TRANSITION TO OCCUR AT PARTITION CL UNO
G03	GUESTROOM CONN	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXG2-PL01	2(2)/A711	2(2)/A711	1/1D010	DF HM DA	EXG2-PT01	45 MIN.	4	

DOOR SCHEDULE - PUBLIC AREAS & BACK-OF-HOUSE

DOOR #	LOCATION	TYPE	DOOR				FRAME				FIRE RATING	HW SET	REMARKS		
			WIDTH	HEIGHT	THKNS	MATERIAL	FINISH	DETAILS		TYPE/ MATERIAL				FINISH	
								HEAD	JAMB						SILL
LEVEL 1															
100.1.1	VESTIBULE	ASD	9'-9 1/8"	7'-9 1/2"	1 3/4"	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	PER MFR.	ASD	CLR ANODIZED	NO RATING	5	AUTOMATIC SLIDING DOOR, EXTERIOR
100.1.2	LOBBY/GREAT ROOM	ASD	9'-10 3/4"	7'-9 1/2"	1 3/4"	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	PER MFR.	ASD	CLR ANODIZED	NO RATING	5	AUTOMATIC SLIDING DOOR, INTERIOR
100.3	PATIO	DP_FGA	3'-6"	7'-9 1/2"	1 3/4"	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	ALUM. SADDLE	SF	CLR ANODIZED	NO RATING	8	
100.6.1	MEETING	DP F SD M	6'-0"	7'-6"	2"	SCWD	EXP-WD02	N/A	N/A	1/1D010	N/A	N/A	NO RATING	19	SLIDING DOOR, COORDINATE SLIDING DOOR TRACK MOUNTING HEIGHT WITH CEILING HEIGHT
100.6.2	MEETING	DP F SD M	6'-0"	7'-6"	2"	SCWD	EXP-WD02	N/A	N/A	1/1D010	N/A	N/A	NO RATING	19	SLIDING DOOR, COORDINATE SLIDING DOOR TRACK MOUNTING HEIGHT WITH CEILING HEIGHT
100.6.3	MEETING	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	NO RATING	16	ADD PEEP HOLE VIEWER
100.7.1	BREAKFAST	DP PSD_WD	5'-0"	7'-8 3/4"	1 1/2"	SCWD	EXP2-WD02	PER MFR.	PER MFR.	N/A	DF PSD	EXP2-WD02	NO RATING	22	SLIDING POCKET DOORS
100.7.2	BREAKFAST	DP PSD_WD	5'-0"	7'-8 3/4"	1 1/2"	SCWD	EXP2-WD02	PER MFR.	PER MFR.	N/A	DF PSD	EXP2-WD02	NO RATING	22	SLIDING POCKET DOORS
100.8.1	PANTRY	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL01	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	45 MIN.	6	PARALLEL ARM CLOSER W/ COMPRESSION STOP HOLD-OPEN
100.8.2	PANTRY	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	45 MIN.	18	
100.9	STORAGE	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	17	
100.10	MEETING ROOM	DP F	PR 3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	17	DOOR VIEWERS (ONE AT ADA)
100.11	MECHANICAL	DP F	4'-0"	6'-8"	1 3/4"	HM	EXP2-PT30	2(1)/A711	1/A711	1/A711	ALUM. SADDLE	DF HM 00	NO RATING	13	EXTERIOR DOOR AND FRAME COLOR TO MATCH ADJACENT EXTERIOR WALL
100.12	SALES	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	14	PROVIDE THROW DEADBOLT/LATCHBOLT
100.13.2	SALES	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	14	PROVIDE THROW DEADBOLT/LATCHBOLT
100.14.1	WORK AREA	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	18	
100.14.2	WORK AREA	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	90 MIN.	24	
100.15	GENERAL MANAGER	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	14	PROVIDE THROW DEADBOLT/LATCHBOLT
100.16	SERVER	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	17	
100.18.1	LAUNDRY	DP F	4'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	90 MIN.	17	
100.18.2	LAUNDRY EQUIPMENT	DP F	2'-0"	6'-8"	1 3/4"	HM	EXP2-PT30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	NO RATING	16	
100.19	GUEST LAUNDRY	DP FG	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	15	
100.20	FITNESS	DP FG	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	45 MIN.	15	
100.21.1	POOL	DP FGA	3'-6"	6'-8"	1 3/4"	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	ALUM. SADDLE	SF	CLR ANODIZED	NO RATING	9	
100.21.2	POOL	DP FGA	3'-6"	6'-8"	1 3/4"	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	1/1D010	SF	CLR ANODIZED	NO RATING	25	
100.22	STORE /AC / BREAK	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	18	
100.23.1	ELECTRICAL	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PT30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	90 MIN.	12	PANIC HARDWARE REQUIRED
100.23.2	ELECTRICAL	DP F	4'-0"	6'-8"	1 3/4"	HM	INT: EXP2-PT30; EXT: TO MATCH EIFS (1C/1N)	1/A711	1/A711	ALUM. SADDLE	DF HM 00	INT: EXP2-PT30; EXT: TO MATCH EIFS (1C/1N)	NO RATING	13	EXTERIOR DOOR AND FRAME COLOR TO MATCH ADJACENT EXTERIOR WALL; PANIC HARDWARE REQUIRED
100.25	LUGGAGE STORAGE	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PT30	1/A711	1/A711	SEE SHEET ID010	DF HM 00	EXP2-PT30	20 MIN.	18	
C101	CORRIDOR	DP FGA	3'-6"	6'-8"	1 3/4"	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	ALUM. SADDLE	SF	CLR ANODIZED	NO RATING	9	
C102	CORRIDOR	DP FGA	3'-6"	6'-8"	1 3/4"	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	ALUM. SADDLE	SF	CLR ANODIZED	NO RATING	9	
C103	ELEVATOR LOBBY	DP FGA	3'-6"	6'-8"	1 3/4"	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	ALUM. SADDLE	SF	CLR ANODIZED	NO RATING	9	
C104	POOL VESTIBULE	DP FG	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	15	CODE REQUIREMENTS MUST BE MET FOR MAXIMUM GLAZING LIFE SIZE & LOCATION
PE01.3	POOL EQUIPMENT	DP F	3'-0"	6'-8"	1 3/4"	HM	EXP2-PT30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	17	
R1	TOILET - WOMENS	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	23	
R2	TOILET - MENS	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	23	
R3	UNISEX EMPLOYEE RR	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	14	PROVIDE THROW DEADBOLT/LATCHBOLT
ST1.1.1	STAIR 1	DP N	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	90 MIN.	20	PANIC HARDWARE REQUIRED; PROVIDE MAGNETIC HOLD-OPEN W/ AUTO RELEASE UPON ACTIVATION OF FIRE ALARM
ST1.1.2	STAIR 1	DP F	3'-0"	6'-8"	1 3/4"	HM	INT: EXP2-PT30; EXT: TO MATCH EIFS (3C/3N)	2(1)/A711	2(1)/A711	ALUM. SADDLE	DF HM 00	INT: EXP2-PT30; EXT: TO MATCH EIFS (3C/3N)	NO RATING	21	EXTERIOR DOOR AND FRAME COLOR TO MATCH ADJACENT EXTERIOR WALL; PANIC HARDWARE REQUIRED
ST2.1.1	STAIR 2	DP N	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	90 MIN.	20	PANIC HARDWARE REQUIRED; PROVIDE MAGNETIC HOLD-OPEN W/ AUTO RELEASE UPON ACTIVATION OF FIRE ALARM
ST2.1.2	STAIR 2	DP F	3'-0"	6'-8"	1 3/4"	HM	INT: EXP2-PT30; EXT: TO MATCH EIFS (4C/4N)	2(1)/A711	2(1)/A711	ALUM. SADDLE	DF HM 00	INT: EXP2-PT30; EXT: TO MATCH EIFS (4C/4N)	NO RATING	21	EXTERIOR DOOR AND FRAME COLOR TO MATCH ADJACENT EXTERIOR WALL; PANIC HARDWARE REQUIRED
LEVEL 2															
CH2	CHUTE CLOSET	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	45 MIN.	7	
H2	HOUSEKEEPING	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	17	
ST1.2	STAIR 1	DP N	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	90 MIN.	20	PANIC HARDWARE REQUIRED
ST2.2	STAIR 2	DP N	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	90 MIN.	20	PANIC HARDWARE REQUIRED
EM2.1	ENG/MAINTENANCE	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	17	
LEVEL 3															
CH3	CHUTE CLOSET	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	45 MIN.	7	
H3	HOUSEKEEPING	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	17	
ST1.3	STAIR 1	DP N	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	90 MIN.	20	PANIC HARDWARE REQUIRED
ST2.3	STAIR 2	DP N	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	90 MIN.	20	PANIC HARDWARE REQUIRED
LEVEL 4															
CH4	CHUTE CLOSET	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	45 MIN.	7	
H4	ELECTRICAL	DP F	6'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	10	
H4	HOUSEKEEPING	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	20 MIN.	17	
ST1.4	STAIR 1	DP N	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	90 MIN.	20	PANIC HARDWARE REQUIRED
ST2.4	STAIR 2	DP N	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/1D010	DF HM 00	EXP2-PT30	90 MIN.	20	PANIC HARDWARE REQUIRED

DOOR HARDWARE GROUPS AND FINISHES

Hardware finishes and base metals shall be listed below, unless otherwise indicated.

Refer to IHG Approved Electronic Door Lockset Guide for list of approved electronic door locksets and information on required finish, fixtures and trim.

Satin stainless steel (US32D) and satin chromium plated (US26D) Finishes and base metals, unless otherwise indicated.

- Exterior Hinges -- US32D on stainless steel.
- Interior Hinges -- US26D on steel.
- Flush Bolts -- US26D on brass or bronze.
- Manual Locks -- US32D on stainless steel.
- Electronic Locks -- See IHG Electronic Door Locks Guide.
- Exit Devices -- 33 Series Sprayed Aluminum.
- Exit Devices -- 99 Series Sprayed Aluminum.
- Pulls, Push Plates/Bars -- US32D on stainless steel.
- Coordinators -- USP on steel.
- Closers -- Sprayed aluminum.
- Overhead Stops/Holders -- US26D on brass or bronze.
- Kickplate -- US32D on stainless steel.
- Door Edge Guards -- US32D on stainless steel.
- Armor Plates -- US32D on stainless steel.
- Stops, Holders -- US26D on brass or bronze.
- Thresholds -- Milled aluminum.
- Miscellaneous -- US26D on brass or bronze.

- Hardware on aluminum doors shall match finish of doors and frame.
- US32 and US32D solid 16-8 chromium-nickel, 300 Series, Austenitic, non-magnetic.
 - Straight chrome-zincs (magnets) are not acceptable, except as hinge pins.
 - For items not available in US32 or US32D provide US26 or US26D.

Door Hardware Groups.

SET 1 - Guestroom Entrance door
Hinges: Qty 3 per leaf 4-1/2 by 4-1/2-inches. Power transfer type hinges.
Lockset/Function: Electronic mortise lockset with throw deadbolt / dead-locking latchbolt on interior room side.
Card Reader: RFID card reader entry. Refer to IHG Approved Electronic Door Locksets Guide.
Privacy Door Latch: Cannot be used to keep door ajar. Can be legally installed on fire-rated openings.
Closer: Parallel arm closer with appropriate mounting and cover. 1 Req'd.
Stop: Floor Stop or