



SPRINKLER FLOW AND TAMPER SWITCH. PROVIDE ONE FLOW AND ONE TAMPER SWITCH FOR EACH SPRINKLER ZONE. FIELD COORDINATE QUANTITIES REQUIRED WITH SPRINKLER CONTRACTOR

1 FIRE ALARM FIRST FLOOR PLAN
 SCALE: 1/8"=1'-0"

| FIRE ALARM SYMBOL LIST | | |
|------------------------|----------------------------------|--------------------------|
| SYMB. | DESCRIPTION | MOUNTING OR AS INDICATED |
| ☒ | FIRE ALARM MANUAL PULL STATION | WALL - 48" AFF |
| ☒ | ANNUNCIATOR AUDIO/VISUAL | WALL - 6"-8" AFF |
| ☒ | COMBINATION HORN/STROBE LIGHT | WALL - 6"-8" AFF |
| ☒ | STROBE LIGHT | WALL - 6"-8" AFF |
| ☐ | FIRE BELL | WALL |
| Ⓢ | SMOKE DETECTOR | CEILING |
| Ⓣ | DUCT DETECTOR | IN MECH. DUCT |
| Ⓜ | HEAT DETECTOR | CEILING |
| ■ | MAGNETIC DOOR HOLDER | WALL |
| □ | SPECIAL DEVICE (AS NOTED) | |
| ☒ | SHUT DOWN RELAY | |
| Ⓣ | FLOW SWITCH (SPRINKLER) | |
| Ⓣ | TAMPER SWITCH (SPRINKLER) | |
| Ⓢ | SMOKE DETECTOR | WALL |
| ☐ | CARBON MONOXIDE DETECTOR | |
| ☒ | FIREMAN'S PHONE | WALL - 48" AFF. |
| ☒ | 2-WAY COMMUNICATION DEVICE | WALL - 48" AFF. |
| ☒ | ANNUNCIATOR PANEL | |
| ☒ | FIRE ALARM CONTROL PANEL (FACP) | |
| ♿ | INDICATES HANDICAP ACCESS SUITE | |
| ♿ | INDICATES HEARING IMPAIRED SUITE | |

NOTE FOR FIRE ALARM SYSTEM:

- FIRE ALARM SYSTEM SHALL BE SEPARATELY PERMITTED AND SUBMITTED BY THE FIRE ALARM CONTRACTOR.

KEY NOTES:

- LOCATION OF CENTRAL CONTROL POINT FOR 2-WAYS COMMUNICATION SYSTEM
- VERIFY LOCATION OF FACP WITH FIRE MARSHAL PRIOR TO INSTALLATION