

FIRE ALARM SYMBOL LIST		
SYMB.	DESCRIPTION	MOUNTING OR AS INDICATED
☒	FIRE ALARM MANUAL PULL STATION	WALL - 48" AFF
☒	ANNUNCIATOR AUDIO/VISUAL	WALL - 6'-8" AFF
☒	COMBINATION HORN/STROBE LIGHT	WALL - 6'-8" AFF
☒	STROBE LIGHT	WALL - 6'-8" AFF
☐	FIRE BELL	WALL
☐	SMOKE DETECTOR	CEILING
☐	DUCT DETECTOR	IN MECH. DUCT
☐	HEAT DETECTOR	CEILING
■	MAGNETIC DOOR HOLDER	WALL
☐	SPECIAL DEVICE (AS NOTED)	
☐	SHUT DOWN RELAY	
☐	FLOW SWITCH (SPRINKLER)	
☐	TAMPER SWITCH (SPRINKLER)	
☐	SMOKE DETECTOR	WALL
☐	CARBON MONOXIDE DETECTOR	
☐	FIREMAN'S PHONE	WALL - 48" AFF.
☐	2-WAY COMMUNICATION DEVICE	WALL - 48" AFF.
☐	ANNUNCIATOR PANEL	
☐	FIRE ALARM CONTROL PANEL (FACP)	
♿	INDICATES HANDICAP ACCESS SUITE	
♿	INDICATES HEARING IMPAIRED SUITE	

NOTE FOR FIRE ALARM SYSTEM:


1. FIRE ALARM SYSTEM SHALL BE SEPARATELY PERMITTED AND SUBMITTED BY THE FIRE ALARM CONTRACTOR.

1 FIRE ALARM SECOND FLOOR PLAN
SCALE: 1/8"=1'-0"

MEP GREEN DESIGN & BUILD, P.L.L.C. RETAINS COPYRIGHT TO THIS DOCUMENT. THE IDEA DESIGN AND DETAILS, AS A PROFESSIONAL AND INTELLECTUAL INSTRUMENT OF SERVICE, AND IS NOT TO BE USED/COPIED IN WHOLE OR IN PART, FOR ANY OTHER PROJECT WITHOUT THE EXPRESSED WRITTEN CONSENT OF MEP GREEN DESIGN & BUILD, P.L.L.C.



FAST AND ACCURATE
JUNE 19, 2023



RSS-ARCHITECTS.COM
817/538-9258

Date 06-19-2023

Job 19060

Sheet

FA2.1